



Certificate of conformity

Presumption of conformity is derived from the tests conducted on representative test sample(s) provided by the manufacturer of the below stated models. These test sample(s) passed the tests according to the applied standards according to the EMC directivity 2004/108/EC and 2014/30/EU. The CE declaration to be provided by the manufacturer cannot be replaced by this document.

Applicant: **SMA Solar Technology AG**
Sonnenalle 1
34266 Niestetal
Germany

Product: **Grid-tied photovoltaic inverter**

Model: **STP 50-40**

Applied rules and standards:

EN 61000-6-3:2007 + A1:2011	IEC 61000-6-3:2006 + A1:2010
EN 61000-6-2:2005	IEC 61000-6-2:2005
EN 61000-6-4:2007 + A1:2011	IEC 61000-6-4:2006 + A1:2010
EN 61000-6-1:2007	IEC 61000-6-1:2005
EN 61000-3-11:2000	IEC 61000-3-11:2000
EN 61000-3-12:2011	IEC 61000-3-12:2011

Documents: **Report**
STP50-40-41:LE2417, dated 2017-06-19
STP50-40-MOW-510:LE2317, dated 2017-06-26

Certificate number: **U17-0385**

Date of issue: **2017-08-10**

