IEC IECEE CB SCHEME	Ref. Certif. No. **DE1-49562**

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

SYSTEME CEI D'ACCEPTATION MUTUELLE DE CERTIFICATS D'ESSAIS DES EQUIPEMENTS ELECTRIQUES (IECEE) METHODE OC

CB TEST CERTIFICATE CERTIFICAT D'ESSAI OC

Product Produit	Crystalline silicon terrestrial photovoltaic modules
Name and address of the applicant Nom et adresse du demandeur	LG Electronics Inc. 191-1 Gongdan-Dong, 730-030 GUMI-CITY KOREA, REPUBLIC OF
Name and address of the manufacturer Nom et adresse du fabricant	LG Electronics Inc. 191-1 Gongdan-Dong, 730-030 GUMI-CITY KOREA, REPUBLIC OF
Name and address of the factory Nom et adresse de l'usine Note: *When more than one factory, please report on page 2* Note: *Lorsque il y plus d'une usine, veuillez utiliser la 2ème page*	LG Electronics Inc. 191-1 Gongdan-Dong, 730-030 GUMI-CITY KOREA, REPUBLIC OF ☐ Additional Information on page 2
Ratings and principal characteristics Valeurs nominales et caractéristiques principales	See additional information on page 2
Trademark (if any) Marque de fabrique (si elle existe)	LG
Type of Manufacturer's Testing Laboratories used Type de programme du laboratoire d'essais constructeur	
Model / Type Ref. Ref. De type	A) LGxxxS1Y-G2; B) LGxxxR1Y-G2; C) LGxxxS1K-G2
Additional information (if necessary may also be reported on page 2) Les informations complémentaires (si nécessaire, peuvent être indiqués sur la 2ème page)	Max. system voltage: DC 1000 V, Class II, Class of application: A, Fire Rating Class C, Max. Reverse current: 15 A ☒ Additional Information on page 2
A sample of the product was tested and found to be in conformity with Un échantillon de ce produit a été essayé et a été considéré conforme à la	**PUBLICATION** **EDITION** IEC 61215(ed.2) IEC 61730-1(ed.1) IEC 61730-2(ed.1)
As shown in the Test Report Ref. No. which forms part of this Certificate Comme indiqué dans le Rapport d'essais numéro de référence qui constitue partie de ce Certificat	924214-3972-0001/160378

This CB Test Certificate is issued by the National Certification Body
Ce Certificat d'essai OC est établi par l'Organisme **National de Certification**

VDE Prüf- und Zertifizierungsinstitut GmbH
VDE *Testing and Certification Institute*
Zertifizierungsstelle / *Certification*

Date: 2012-01-06 Signature: E. Biehl

Additional information (if necessary)
Information complémentaire (si nécessaire)

xxx in the type number replaces the power in Watt at STC and can be any number between 230 and 280 for A) and C) 210 and 250 for B).
Y in the type number replaces color of frame and can be C for black or W for white.

VDE Prüf- und Zertifizierungsinstitut GmbH
VDE *Testing and Certification Institute*
Zertifizierungsstelle / *Certification*

Date: 2012-01-06

Signature: E. Biehl